



Your Ref. Date: 15 / 3 / 2021

Applicant: شركة طيبة للتوريدات والهندسة


Lab. Ref. No.: MTL/ 694 - 1 / 2021

Specimens: غرفة تأريض خرسانية موردة بمعرفة العميل


Date : 17 / 3 / 2021

## RESULTS OF LOADING TEST

No.	Weight (kg)	Average Measured Dimensions (mm)	Loaded Area	Ultimate Load (kN)	REMARKS
1	36.640	322*322*228	Square 100*100 mm	35.250	////////////////////



Specimen



Loading of Specimen



Failure Shape



Head of Materials Testing Lab

(Dr. Hatem Hassan Ibrahim)